

# A Winning Approach to the Greening of Labs – A Case Study

Presented by B2Q Associates, Inc.

Chris Schmidt & Brad Newell



*A Woman Business Enterprise (WBE)*



UMass  
Amherst

- ISB
- ELAB II

# Learning Objectives

1. Improve ability to identify, develop, implement, and maintain a successful lab energy efficiency and optimization project by taking a step-wise and multi-disciplinary approach.
2. Increase awareness of the importance of a collaborative team approach as a main driver of the success of lab safety and energy optimization projects – building the right team.
3. Provide a deeper understanding of the interaction between lab ventilation and fume hood controls in terms of safety, performance, and energy.
4. Highlight the importance of identifying changes in use, updated standards, and the ability to account for future changes in lab use or standards.

# Project Introduction


Recent projects at the University of Massachusetts Amherst, and co-sponsored by Eversource Energy and DCAMM, provided the opportunity for B2Q to develop a stepwise, multidisciplinary approach to optimizing lab buildings

## 5 Step Process

1. Multi-Building Scoping Audits
2. Focused Lab Optimization Studies on Selected Lab Buildings
3. Implementation, Commissioning & Owner Training
4. Measurement & Verification of Safety and Savings
5. Persistence via Communication & Continuous Commissioning

- **Integrated Sciences Building (ISB) – 8 years old**
  - 150,000 ft<sup>2</sup> (85,000 ft<sup>2</sup> of Lab Space)
  - 4,620,580 kWh - Baseline
  - 29,000 MLbs Steam - Baseline
  - **\$1,042,058** in Energy Annually – Baseline
  - EUI: 275 kBtu/ft<sup>2</sup> – Baseline (2015)
- **Engineering Lab II (ELab II) – 13 years old**
  - 61,000 ft<sup>2</sup> (21,474 ft<sup>2</sup> of Lab Space)
  - 2,636,348 kWh - Baseline
  - 15,096 MLbs Steam - Baseline
  - **\$565,554** in Energy Annually – Baseline
  - EUI: 359 kBtu/ft<sup>2</sup> – Baseline (2015)


# One Approach with 3 Key Aspects to Cost Effective, Multi-Building Lab Optimization Projects




# Step 1 – Scoping Audits

## 1. Multi-Building Scoping Audits

- Provide a quick look at numerous buildings to provide high level insight to lab optimization and energy savings opportunities
- Building level and sample lab ACH examined
- Serve as a “go/no-go” screening for further evaluation



# Step 1 – Scoping Audits



- Small, concentrated project team
- Facilitates the communication of details and allows all major parties to track progress of scoping studies
- Project results were discussed and laid out in a stakeholder meeting


# Step 1 – Scoping Audit Results

© 2021 B2Q Associates


| Integrated Science Building - Energy Efficiency Measures (EEMs) Executive Summary  |   |                  |             |   |               |                    |                    |                       |                             |
|--|---|------------------|-------------|---|---------------|--------------------|--------------------|-----------------------|-----------------------------|
| EEM-#  | Measure Description                           | Electric Savings | CHW Savings | Electric Cost Savings                             | Steam Savings | Steam Cost Savings | Total Cost Savings | Project Cost Estimate | Potential Utility Incentive |
|  |   | kWh              | kWh         | \$  | MLbs          | \$                 | \$                 | \$                    | \$                          |
| 1  | Repair Cooling Leakby on AHU-1.4              | 195,908          | 195,908     | \$19,591  | 6,692         | \$133,831          | \$153,422          | \$7,700               | \$17,632                    |
| 2  | Optimize Enthalpy Wheel Control on Lab AHUs   | 109,796          | 109,796     | \$10,980  | 402           | \$8,039            | \$19,018           | \$30,000              | \$9,882                     |
| 3  | Optimize Admin AHU Control                    | 76,450           | 76,450      | \$7,645   | 1,534         | \$30,676           | \$38,321           | \$102,300             | \$6,880                     |
| 4  | Implement Static Pressure Setback on Lab AHUs | 46,513           | 0           | \$4,651   | 0             | \$0                | \$4,651            | \$16,000              | \$4,186                     |
| 5  | Reduce Ventilation Airflow to Lab Spaces      | 671,369          | 3,118       | \$67,137  | 786           | \$15,728           | \$82,865           | \$296,000             | \$60,423                    |
| Totals (Excluding EEM-8.B)   |   | 1,100,036        | 385,271     | \$110,004   | 9,414         | \$188,273          | \$298,277          | \$452,000             | \$99,003                    |
| Baseline Energy Consumption  |   |                  | Reduction   | Simple Payback Before Potential Incentive:        |               |                    |                    |                       | 1.5                         |
| Annual Total Electric Use (kWh/yr)   |   | 3,773,534        | 19%         | Eversource RCx Measure Incentive Rate (\$/kWh):   |               |                    |                    |                       | \$0.09                      |
| Annual HVAC Electric Use (kWh/yr)  |   | 2,242,689        | 32%         | Potential Electric Incentive from Eversource:     |               |                    |                    |                       | \$99,003                    |
| Annual Steam Use (MLbs/yr)   |   | 29,226           | 32%         | Net Project Cost After Potential Incentive:       |               |                    |                    |                       | \$352,997                   |
| Annual Chilled Water Use (kWh/yr)  |   | 847,046          | 45%         | Simple Payback After Potential Utility Incentive: |               |                    |                    |                       | 1.2                         |
| *The values in the "CHW Savings" column are shown for informational purposes only. These savings are included in the Total Steam Savings column.         |   |                  |             |   |               |                    |                    |                       |                             |
| **The electric savings shown in the "CHW Savings" column are savings that would come from the ISB chiller plant and not directly the ISB electric meter. |   |                  |             |   |               |                    |                    |                       |                             |

# Step 2 – Focused Lab Optimization Study

2. The most promising buildings with lab savings opportunities are investigated further in a Focused Lab Optimization Study



# Step 2 – Focused Lab Optimization Study



Lab Ventilation Effectiveness Performed by Ralph Stuart, CIH


## 2. Focused Lab Optimization Studies on Selected Lab Buildings

- Project team starts to broaden and include specific sub contractors and parties which specialize in certain areas
- Allows for accurate energy savings and cost estimates as well as building specific solutions built from the lab up

# Step 2 – Focused Lab Optimization Study Results

| Integrated Science Building - Energy Efficiency Measures (EEMs) Executive Summary  |   |                        |             |   |               |                    |                    |                        |                              |
|--|---|------------------------|-------------|---|---------------|--------------------|--------------------|------------------------|------------------------------|
| EEM  | Measure Description   | Total Electric Savings | CHW Savings | Electric Cost Savings                                   | Steam Savings | Steam Cost Savings | Total Cost Savings | Project Cost Estimates | Potential Utility Incentives |
|  |   | kWh/yr                 | kWh/yr      | \$/yr   | Mlbs/yr       | \$/yr              | \$/yr              | \$/yr                  | \$                           |
| Measures from Previous Study   |   |                        |             |   |               |                    |                    |                        |                              |
| 1  | Repair Cooling Valves on AHU-1.4  | 195,908                | 195,908     | \$19,591  | 6,692         | \$133,840          | \$153,431          | \$12,250               | \$35,263                     |
| 2  | Optimize Enthalpy Wheel Control on Lab AHUs & Tie AHU-1.2 Wheel into Metasys      | 109,796                | 109,796     | \$10,980  | 402           | \$8,040            | \$19,020           | \$33,250               | \$19,763                     |
| 3  | Optimize Admin AHUs - OA, DCV, Admin Dampers, Return Air Ductwork Restriction     | 76,450                 | 76,450      | \$7,645   | 1,227         | \$24,540           | \$32,185           | \$99,092               | \$13,761                     |
| 4  | Implement Static Pressure Setback on Lab AHUs & Install Building-Level dP Sensors | 46,513                 | 0           | \$4,651   | 0             | \$0                | \$4,651            | \$30,064               | \$8,372                      |
| Measures from Current Focused Lab Study  |   |                        |             |   |               |                    |                    |                        |                              |
| 5A   | Optimize Laboratory Airflow Control & Set Occ/Unocc Min ACH Rates                 | 460,054                | 48,858      | \$46,005  | 2,211         | \$44,216           | \$90,222           | \$98,240               | \$82,810                     |
| 5B   | Convert Fume Hoods to Variable Volume Control, Reduce Minimums, & Recertify       | 498,392                | 52,930      | \$49,839  | 2,395         | \$47,901           | \$97,740           | \$97,300               | \$89,711                     |
| Additional Measure Identified  |   |                        |             |   |               |                    |                    |                        |                              |
| 6  | Reduce Non-Lab VAV Min Airflows   | 75,000                 | 5,000       | \$7,500   | 750           | \$15,000           | \$22,500           | \$86,638               | \$13,500                     |
| Totals   |   | 1,462,113              | 488,942     | \$146,211   | 13,677        | \$273,537          | \$419,748          | \$456,834              | \$263,180                    |
| Baseline Energy Consumption  |   |                        | Reduction   | Simple Payback Before Potential Incentive: 1.1          |               |                    |                    |                        |                              |
| Annual Total Building Electric Use (kWh/yr)  |   | 3,773,534              | 26%         | Eversource RCx Measure Incentive Rate (\$/kWh): \$0.18  |               |                    |                    |                        |                              |
| Annual Building HVAC Electric Use (kWh/yr)   |   | 2,242,689              | 43%         | Potential Electric Incentive from Eversource: \$263,180 |               |                    |                    |                        |                              |
| Annual Building Steam Use (Mlbs/yr)  |   | 29,226                 | 47%         | Net Project Cost After Potential Incentive : \$193,654  |               |                    |                    |                        |                              |
| Annual Building Chilled Water Use (kWh/yr)   |   | 847,046                | 58%         | Simple Payback After Potential Incentive: 0.5           |               |                    |                    |                        |                              |
| *The values in the "CHW Savings" column are shown for informational purposes only. These savings are included in the Total Electric Savings Column.      |   |                        |             |   |               |                    |                    |                        |                              |
| **The electric savings shown in the "CHW Savings" column are savings that would come from the ISB chiller plant and not directly the ISB electric meter. |   |                        |             |   |               |                    |                    |                        |                              |

Focused Lab  
Optimization Study  
Results



# Increased Lab Awareness



Sound lab practices  
already in place


- During the focused lab study and, specifically, the presentation of results, lab awareness of campus EH&S and lab occupants is greatly increased.
- Answers can be presented to questions such as:
  - How and why do our labs operate in this fashion?
  - How much does it cost to operate these labs?
  - What procedures should be carried out annually to maintain lab spaces?
- This is a great time to educate lab occupants and coordinators
  - This benefits not only their safety, but also helps maintain savings and makes them aware of costs
- This was accomplished through a project review meeting with attendees from the Dean of Engineering down to Lab PIs

# Step 3 – Implementation, Cx & Training

## 3. Implementation

- Engineer new lab control sequences, setpoints and lab airflow offsets to control to CIH recommended Air Change Rates. Setpoints and control sequences approved by EH&S.
- Example Net Room Volume = 11,813 ft<sup>3</sup> with a recommended 6 occupied ACH. Furniture volume was subtracted from gross room volume.

$$6 \text{ ACH} = \frac{\text{Flow Rate} \left( \frac{\text{cu. ft}}{\text{min}} \right) * 60 \left( \frac{\text{min}}{\text{hr}} \right)}{11,813 \text{ (cu. ft)}} = \frac{6 * 11,813}{60} = 1,181 \text{ CFM}$$



# Step 3 – Implementation, Cx & Training

## 3. Implementation

- Engineer new fume hood controls and setpoints to be in line with ANSI Z9.5-2012 standards as well as UMass EH&S standards for face velocity.
- Lower closed sash minimum airflow setpoints, control to 80 fpm face velocity above 4" sash position, use sash status as a backup to lab occupancy sensor

| Fume Hood Min & Max Flows |            |            |               |                 |          |          |
|---------------------------|------------|------------|---------------|-----------------|----------|----------|
| Fume Hood                 |            |            | Base          |                 | Proposed |          |
| Hood Type                 | Hood Width | Hood Count | Occupied Flow | Unoccupied Flow | Max Flow | Min Flow |
|                           | (ft)       | No.        | (cfm)         | (cfm)           | (cfm)    | (cfm)    |
| Low Flow                  | 4          | 4          | 530           | 190             | 450      | 120      |
|                           | 5          | 1          | 550           | 220             | 575      | 160      |
|                           | 6          | 62         | 600           | 300             | 700      | 200      |
|                           | 7          | 40         | 720           | 360             | 800      | 225      |
|                           | 8          | 2          | 835           | 415             | 950      | 250      |
| By Pass                   | 4          | 17         | 530           | 190             | 450      | 120      |
|                           | 6          | 7          | 860           | 300             | 700      | 200      |
|                           | 8          | 4          | 1,195         | 415             | 950      | 250      |
| Pass Thru                 | 6          | 10         | 920           | 450             | 700      | 200      |


# Step 3 – Implementation, Cx & Training

## 3. Commissioning

- Each lab underwent thorough testing and commissioning.
  - Each control sequence was tested for operation during occupied/unoccupied periods, fume hood use/non-use, heating and cooling, emergency purge modes to ensure that the optimized controls and new exhaust setpoints were being maintained
  - Each fume hood was tested and re-certified to verify proper operation
- Through this process, 96 mechanical issues were discovered and were causing labs to not be able to control to their new setpoints leaving unsafe conditions

|            | VAVs With Broken Actuators | VAVs in Need of Repair | VAVs with Flow Fluctuation | Hunting VAVs & Programming Issues |
|------------|----------------------------|------------------------|----------------------------|-----------------------------------|
| Lab Wing   | 33                         | 9                      | 9                          | 29                                |
| Admin Wing | 10                         | 6                      | 0                          | 0                                 |
| Total      | 43                         | 15                     | 9                          | 29                                |

# Step 3 – Project Team



- Hundreds of hours of day to day communication about issues encountered and progress made keep all parties informed and up to speed
- All parties participated in training where project details were reviewed and presented to Facilities Staff and Lab PIs

# Lesson Learned - The Importance of TAB to Lab Safety

- After implementation the BAS was controlling to the correct lab offset as programmed by the controls contractor.

|                        |     | Original K-Factor |                 | New K-Factor |                 |
|------------------------|-----|-------------------|-----------------|--------------|-----------------|
|                        |     | TAB Reading       | Metasys Reading | TAB Reading  | Metasys Reading |
| General Exhaust Flow   | cfm | 3,681             | 4,065           | 4,018        | 4,027           |
| Total Fume Hood Flow   | cfm | 200               | 200             | 200          | 200             |
| Total Supply Flow      | cfm | 4,091             | 3,786           | 3,696        | 3,751           |
|                        |     |                   |                 |              |                 |
| Offset Setpoint        | cfm |                   | -500            |              | -500            |
| Actual Measured Offset | cfm | 210               | -479            | -522         | -476            |


- A K-Factor (or pickup gain) relates pressure velocity and area to airflow in VAVs (and other flow applications)

# Step 4 – Measurement and Verification

## 4. M&V

- Separate from the commissioning effort which ensured the changes made were operating as intended, the M&V process observed the impact on building energy use as a result of the measures implemented
- M&V was critical for the Utility to provide project funding to help pay for the lab optimization projects and provide UMass Management & EH&S with peace of mind that these energy savings are real and being maintained
  - Measured and verified energy savings were compared to predicted energy savings

# Step 4 – Measurement and Verification - ISB




# Step 4 – Measurement and Verification – Final Results

| UMass ISB & Elab II Measured and Verified Savings |                               |                      |                     |                     |                                 |
|---|-------------------------------|----------------------|---------------------|---------------------|---------------------------------|
| Building  | Total Electric Energy Savings | Steam Energy Savings | Energy Cost Savings | Implementation Cost | Simple Payback Before Incentive |
| --  | kWh                           | Mlb                  | \$                  | \$                  | yrs.                            |
| ISB   | 1,851,862                     | 10,738               | \$399,946           | \$590,968           | 1.5                             |
| Elab II   | 677,294                       | 6,312                | \$193,968           | \$448,907           | 2.3                             |
| <b>Total</b>                                      | <b>2,529,156</b>              | <b>17,050</b>        | <b>\$593,914</b>    | <b>\$1,039,875</b>  | <b>1.8</b>                      |

- M&V savings amount to greater than 30% savings of baseline energy use
- M&V savings exceeded predicted savings by >20%

# Early and Consistent Teamwork & Communication


1. Key to project success during all project phases.
2. Allows an open stage to voice questions and concerns from different vantage points
3. No one gets left in the dark about changes in lab operation
4. Allows input from all parties where critical decisions are made before project implementation
5. Allows for the safest, most energy efficient and best functioning final product where **all parties are aware of the changes made and why.**



# Step 5 - Maintaining Persistence Over Time


## 5. Maintaining Persistence Over Time

- Communication
  - While early and consistent teamwork is important to project success, it is equally important to maintain this level of communication after project completion
  - Labs are fluid environments and change constantly
    - With lab alteration, safe ventilation requirements may also change and the recently updated controls must be altered to meet them
    - For this to happen, the need for re-evaluation must be communicated from the Lab Coordinator, through EH&S and Facilities on up to the controls contractor or technician.



# Step 5 - Maintaining Persistence Over Time

- Continuous Commissioning
- B2Q installed FacilityConneX, a Monitoring Based Commissioning software in the integrated sciences building to continuously monitor critical lab operating points and raise flags if operation is not as intended



# Environmental Impact – “Greening”

- If the annual energy savings realized at ISB & ELab II are maintained through persistence for **20** years...
- **50,583 MWh & 4.6 Million Therms of Natural Gas will be saved**

| Year                   | CO <sub>2</sub> (tons) <sup>1</sup> | NO <sub>x</sub> (tons) <sup>1</sup> | SO <sub>2</sub> (tons) <sup>1</sup> |
|------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| 1 Year                 | 2,500                               | 1.1                                 | 0.4                                 |
| <b><u>20 Years</u></b> | <b><u>50,000</u></b>                | <b><u>22</u></b>                    | <b><u>8</u></b>                     |

or

## The Equivalent<sup>2</sup> of:

- **403** passenger vehicles annually
- **211,797** gallons of gas consumed annually
- **2,059,345** pounds of coal burned annually
- **48,780** trees planted annually

<sup>1</sup>Emissions factors are an aggregate from <https://www.eia.gov/electricity/state/massachusetts/> and Solar Gas Turbine Published Emissions Data

<sup>2</sup>Equivalent greenhouse gas factors from: <https://www.epa.gov/energy/greenhouse-gas-equivalencies-calculator>



*A Woman Business Enterprise (WBE)*

100 Burt Rd. Ste. 212  
Andover, MA 01810

Chris Schmidt – Senior Project Manager  
[cschmidt@b2qassociates.com](mailto:cschmidt@b2qassociates.com)  
(603) 247-1575 (Cell)

Brad Newell – Project Manager  
[bnewell@b2qassociates.com](mailto:bnewell@b2qassociates.com)  
(603) 703-3932 (Cell)  
(978) 447-5604 (Office)

# Questions?

## Acknowledgements:

- University of Massachusetts Amherst
  - Physical Plant, EH&S
- DCAMM
- Eversource
- Ralph Stuart, CIH & Rob Klein, MS, CIH
- Howse Corporation
- Lab Controls Systems
- FlowTech
- Performance Test & Balance
- Adams Plumbing and Heating
- SEMCo
- FacilityConneX